

## Installing underground cable – open trench method

1. A trench approximately two metres wide and two metres deep will be excavated for each cable
2. During construction the working width of land needed would be between 30 to 40 metres
3. Jointing bays are needed where one section of cable joins the next
4. When land is reinstated, land-use restrictions may apply to avoid risk of cables being disturbed or damaged

